



HUDSON
ENGINEERING
&
CONSULTING, P.C.

SITE ADDRESS: 45 Northfield Avenue

TOWN/VILLAGE: Dobbs Ferry

DATE: 10/21/2021 TIME: 9:15am

WEATHER: Sunny TEMP. 58° F

WITNESSED BY: Nicholas Shirriah

DEEP TEST HOLE DATA SHEET – STORMWATER MANAGEMENT SYSTEM

DEPTH	HOLE NO. <u>1</u>	HOLE NO. <u>2</u>	HOLE NO. <u>3</u>	HOLE NO. <u>4</u>
G.L.	0 – 20"			
6"	Organic soil w/			
12"	Roots			
18"				
24"	20 – 48"			
30"	Dark loam			
36"				
42"	48 – 68"			
48"	Grey fill w/			
54"	Debris			
60"				
66"	68 – 96"			
72"	Brown sandy			
78"	Loam			
84"				
90"	No GW			
96"	No Ledge			
102"				
108"				

- Indicate level at which Ground Water (GW), Mottling and/or Ledge Rock is encountered.
- Indicate level for which water level rises after being encountered.

EXCAVATION PERFORMED BY: PRECISION FIELD TESTING