



HUDSON
ENGINEERING
&
CONSULTING, P.C.

December 9, 2021
Anthony Oliveri, P.E.
Consulting Engineer
570 Taxter Road, Suite 300
Elmsford, NY 10523

Re: Site Plan Review
54 Clinton Avenue
Village of Dobbs Ferry, NY 10522

Dear Anthony Oliveri,

On behalf of the applicant, our office has reviewed your Memorandum dated December 8, 2021, and offers the following responses:

- 1.) Provided under separate cover.
- 2.) Provided under separate cover.
- 3.) The storm drain cleanout has been correctly called out on sheet C-1.
- 4.) A concrete washout and concrete detail have been added to sheet C-1 and C-2 respectively.
- 5.) The callout for the 18"x18" precast drain inlet on sheet C-1 has been revised to indicate an 18" sump instead of a 1' sump.

We respectfully request that you review the enclosed submittal. If you should have any additional questions or comments, please do not hesitate to contact our office at (914) 909-0420, or via email at shea@hudsonec.com.

Thank you.

Sincerely,



Shea Graham,
Project Engineer