

Dolph Rotfeld Engineering Division

570 Taxter Road, Suite 300 Elmsford, NY 10523 (914) 631-8600 phone (914) 631-5769 fax www.drepc.com www.aiengineers.com

MEMORANDUM

TO: Stephen Hunter, Planning Board Chairman

CC: Planning Board Members

Dan Roemer, Building Inspector Dan Pozin, Planning Board Attorney Valerie Monastra, Village Planner

FROM: Anthony Oliveri, P.E.

DATE: April 4, 2023

RE: Site Plan Review

99 Oliphant Avenue

Village of Dobbs Ferry, New York

With regard to the above-mentioned project, this office has reviewed the following plans and submittals:

- Survey prepared by Aristotle Bournazos, P.C., dated 9/8/2021,
- Letter to AHRB from Christina Griffin Architects, dated 3/16/2023,
- Various Documents (Letters from neighbors, LWRP Consistency Review Coastal Assessment, Site plan Development checklist, Land Use Approval Application, Architectural & Historical Review Board Application, Board lawn sign, Etc.)

This plan has not been reviewed by this office for compliance with the zoning code.

Project Description: Renovations and additions to an existing single-family residence.

Our comments are as follows:

Applicant states there is an increase of impervious area of 36 sf and the stormwater will be connected into the existing underground drainage system. Verification as to sizing and functionality of the existing SC-740 Stormtech chamber should be conditional of any building permit.

Thank You