



HUDSON
ENGINEERING
&
CONSULTING, P.C.

July 1, 2021

Anthony Oliveri, P.E.
Dolph Rotfeld Engineering
570 Taxter Road, Suite 300
Elmsford, NY 10523

Re: Site Plan
185-191 Ashford Avenue
Dobbs Ferry – New York

Dear Mr. Oliveri:

We have received your comment letter dated June 29, 2021, and offer the following responses:

1. Comment shall be addressed during Planning board meeting.
2. The existing sewer service will be TV inspected and verified. Any defects shall be corrected prior to reuse to the satisfaction of the Village Engineer.
3. Proposed porous paver area has been better delineated on the site plan.
4. The drain at the bottom of the ramp is connected to the pump basin. The discharge for the footing drain discharges to the 18"x18" catch basin as shown on the plan C-3.
5. More detail regarding the retaining wall shall be shown on the foundation plans.
6. As per discussion with Mr. Oliveri, the comment has been satisfied.

If you should have any additional questions or comments, please do not hesitate to contact our office at (914) 909-0420, or via email at david@hudsonec.com.

Sincerely,

David Young
Project Engineer