

Village of Dobbs Ferry
New York

Gould Park Improvements 2023

ADDENDUM NO. 3
September 8, 2023




The following revisions are being issued to the Contract Specifications and Drawings for the above referenced Project.

- 1) See attached Sheet E-101: Electrical Site Plan, the Luminaire schedule previously stated, "Provided and installed by Musco." However, the lighting fixtures, poles and related equipment shall be provided and installed by the contractor.

The contractor shall sign for the receipt of addendum in Section C, page C-4.

THIS ADDENDUM MUST BE SUBMITTED TOGETHER WITH THE ORIGINAL SPECIFICATIONS AND CONTRACT DOCUMENTS BOOK. SUBMIT THIS ADDENDUM IN ITS ENTIRETY.



LUMINAIRE SCHEDULE						
SYMBOL	LABEL	MANUFACTURER	CATALOG NUMBER	LUMENS	WATTS	POLE
	A	MUSCO LIGHTING	TLC-LED-550, LED 5700K, 75 CRI, PROVIDED AND INSTALLED BY MUSCO	67000 x 2	540 x 2	P1 40', PROVIDED AND INSTALLED BY MUSCO
	B	KLIK LED	LP 40 XXX A 40, LED FIXTURE FOR USE IN HAND RAIL			
	C	KLIK LED	LP 40 XXX A 40, LED FIXTURE FOR USE IN HAND RAIL			

[illegible]